

# Gender Influences in Indoor Air Quality Perception for Individuals in Tropical Climate

Gustavo S Graudenz<sup>1,2\*</sup>, Joao Alexandre Paschoalin-Filho<sup>1</sup>, Andreza Portella Ribeiro<sup>1</sup> and Arlindo Tribess<sup>3</sup>

<sup>1</sup>Environmental Management and Sustainability Master Program, University Nove de Julho, Sao Paulo, Brazil

<sup>2</sup>Medical Science Department, University Nove de Julho, Sao Paulo, Brazil

<sup>3</sup>Departments of Mechanical Engineering, Polytechnic School, University of Sao Paulo, Brazil

## Abstract

Gender differences in indoor air quality perception are still controversial and geographic and climate variations can alter substantially the perceived indoor air quality. The aim of this study was to compare differences and analyze data on indoor air quality perception between genders in individuals living in the tropics. To address this question thirty-three subjects grouped by gender were exposed to 14, 18, 22 and

26 degrees Celsius (°C) - or correspondingly, 57.2, 64.4, 71.6 and 78.8 degrees Fahrenheit (F) - with a relative humidity of the indoor air of 65 ± 7% in an experimental office environment. Results were obtained by a self-administered visual analogue scale questionnaire and analyzed using mean score comparisons and principal component analysis of indoor air perception. The results demonstrated that apart from colder temperatures far from thermoneutrality both groups showed no differences in IAQ scores and very close patterns of indoor air quality perception. This study suggests a role for other contributing factors as cultural and dressing habits as determinants to gender differences in indoor air-quality perception concerning individuals living in tropical climate.

**Keywords:** Indoor air quality; Building-related illness; Air conditioning; Experimental studies

## Introduction

Urban populations are spending increasing periods of time indoors due to indoor air quality and review and world health organization changes in lifestyle that have taken place in the last decades. Indoor Air Quality (IAQ) related problems are the environmental health issue most commonly related to occupational respiratory problems, but factors associated with perceived IAQ are complex and include temperature, humidity, air-exchange rates, odors, contaminants, labor, and host-related factors [1,2]. Importantly, the use of air conditioning systems is consistently associated with respiratory symptoms when compared to natural ventilation also in tropical climates [3,4].

There is increasing evidence that temperature and relative humidity are determinants for IAQ perception and related respiratory symptoms, but their specific effects in different subsets of the population are yet to be determined [5].

There is a consistent association between female gender and indoor air complains in air-conditioned working environments, but there is much controversy regarding its cause [6,7]. There is evidence to believe that the reason for the difference resides in women being more prone to work-related, adverse psychological conditions and that they differ from men with regard to thermal perception *per se*, as a result of their lower skin temperature and evaporative loss [8-10]. The traditional method of calculating comfort indices based on predicted mean vote (PMV) and predicted percentage dissatisfied (PPD) using physical data and thermal sensations is widely accepted [11]. However, these indices cannot isolate the patterns of subjective information of indoor air perception that are combined to form the final indices. The use of principal components factor analysis can add a new perspective in IAQ studies, for in this approach no variable is considered as a dependent variable [12]. Instead, it makes patterns of correlated variables responsible for cumulative variances. This data analysis of subjective information can add valuable information to the traditional comparison of means of groups from analogue perception scales [13].

The aim of this study was to compare men and women with regard to patterns of IAQ perception under constant relative humidity and different temperatures in an experimental office environment, by means of a visual analogue scale of IAQ.

## Subjects and Methods

### Subject selection

The present study was approved by the ethics committee of the State University of Sao Paulo, Brazil. After providing informed consent, individuals were selected from a population subset aged from 20 to 45 years. Subjects were not under treatment for endocrine, infectious or rheumatologic diseases. Subjects underwent a medical history and physical examination. The male group consisted of 17 individuals, and the female group consisted of 16 women aged matched with the male group.

All enrolled subjects were invited to fill out the reduced visual analogue scale (VAS) regarding IAQ and respiratory symptoms proposed by Kildeso during the temperature tests [14] (Figure 1). This scale consists of seven different questions concerning general ideas of indoor air quality and related parameters. Individuals were instructed to complete the scale by plotting their perceptions according to intensity on a 100 mm-long line with the extremes of perception at given intervals.

**\*Corresponding author:** Gustavo Silveira Graudenz, GeAS – UNINOVE, Rua Francisco Matarazzo 612, São Paulo, Brazil, Tel: 55 11- 70289141; Fax: 55 11- 36659301; E-mail: [graudenz@uninove.br](mailto:graudenz@uninove.br)


**Received** October 09, 2013; **Accepted** November 22, 2013; **Published** November 29, 2013

**Citation:** Graudenz GS, Paschoalin-Filho JA, Ribeiro AP, Tribess A (2013) Gender Influences in Indoor Air Quality Perception for Individuals in Tropical Climate. *Occup Med Health Aff* 1: 142. doi:[10.4172/2329-6879.1000142](http://dx.doi.org/10.4172/2329-6879.1000142)

**Copyright:** © 2013 Graudenz GS, et al. This is an open-access article distributed under the terms of the Creative Commons Attribution License, which permits unrestricted use, distribution, and reproduction in any medium, provided the original author and source are credited.

### Temperature tests

The selected population wore standardized thermal protection clothing of 1.0 CLO unit [15]. Temperature tests were performed in a



Parameter	Temperature	Female (mean ± SE)	Male (mean ± SE)	P value #
Hot air sensation	14°C	1.58 ± 0.37	2.53 ± 0.27	0.016
	18°C	2.92 ± 0.31	3.11 ± 0.25	0.733
	22°C	5.77 ± 0.36	5.95 ± 0.31	0.508
	26°C	6.03 ± 0.44	6.49 ± 0.29	0.417
Dry air sensation	14°C	4.99 ± 0.44	4.70 ± 0.39	0.505
	18°C	5.05 ± 0.40	5.41 ± 0.39	0.344
	22°C	6.07 ± 0.38	5.59 ± 0.32	0.268
	26°C	5.36 ± 0.35	5.51 ± 0.26	0.194
Little ventilation (Stagnant air)	14°C	4.87 ± 0.30	5.53 ± 0.50	0.550
	18°C	4.88 ± 0.40	4.45 ± 0.31	0.850
	22°C	6.29 ± 0.36	6.44 ± 0.50	0.940
	26°C	5.36 ± 0.47	4.61 ± 0.54	0.105
Good indoor air quality	14°C	6.97 ± 0.56	6.89 ± 0.52	0.828
	18°C	5.53 ± 0.58	6.75 ± 0.45	0.108
	22°C	5.97 ± 0.43	6.31 ± 0.59	0.597
	26°C	5.57 ± 0.58	7.18 ± 0.54	0.131
Easy mental concentration	14°C	8.59 ± 0.39	8.86 ± 0.19	0.870
	18°C	8.19 ± 0.55	8.92 ± 0.39	0.393
	22°C	8.18 ± 0.72	8.99 ± 0.21	0.858
	26°C	8.79 ± 0.33	8.61 ± 0.28	0.236
In good shape (fresh)	14°C	7.85 ± 0.64	8.56 ± 0.30	0.913
	18°C	7.98 ± 0.69	8.84 ± 0.32	0.569
	22°C	8.42 ± 0.54	8.71 ± 0.44	0.955
	26°C	8.15 ± 0.55	8.38 ± 0.43	0.557
Well-being	14°C	8.20 ± 0.49	8.91 ± 0.23	0.281
	18°C	9.09 ± 0.31	9.32 ± 0.24	0.478
	22°C	8.86 ± 0.39	8.91 ± 0.27	0.850
	26°C	8.76 ± 0.31	8.58 ± 0.27	0.358

**Table 1:** Perception scores at different temperatures. Comparison of mean scores of indoor quality perception at different temperatures for males and females. (# = Mann Whitney U test).

Parameter	Temperature 14°C (57.2°F)			Temperature 18°C (64.4°F)			Temperature 22°C (71.6°F)			Temperature 26°C (78.8°F)		
	1	2	3	1	2	3	1	2	3	1	2	3
Hot air sensation			.965	-.330		.837		.883		-.353	.675	0.400
Dry air sensation		.816	.335		.888		-.403	.841		.410	-.349	0.757
Little ventilation (stagnant air)		-.805		-.644	.315		-.778					0.785
Good indoor air quality	.519	.357			-.838				.942		.742	
Easy mental concentration	.866				-.311	.510	.569	.356	.489	.790		
In good shape (fresh)	.937			.638		.708	.887			.805		
Feeling good (well-being)	.875			.888			.672	-.638		.651	.645	
Cumulative variance (%)	38.25	59.84	76.35	32.89	56.97	71.75	42.44	65.50	80.35	34.82	56.53	73.93
KMO	0.541			0.348			0.508			.368		

**Table 2:** Principal components in female individuals at different temperatures. Rotated component matrix selected by principal component analysis for temperatures of 14, 18, 22, and 26°C (57.2, 64.4, 71.6, and 78.8°F) in female individuals. KMO= Kaiser-Meyer-Olkin measure of sampling adequacy.

heat- and humidity-controlled 34.8 m<sup>2</sup> chamber isolated from sound, light, and natural ventilation already described in other chamber studies [16] (The chamber's air supply came exclusively from a fan coil with a nominal output of 340 m<sup>3</sup>/h and from a chiller with 5 tons of refrigeration capacity. The experimental system ensured air exchange rates of more than 27 m<sup>3</sup>/hour/person. Levels of indoor pollution were monitored for biological (viable fungal spores), inorganic (total particulate matter) and personal (carbonic dioxide levels) pollutants. Subjects were exposed to different thermal conditions of 14, 18, 22 and 26 degrees Celsius (°C) – or, correspondingly, 57.2, 64.4, 71.6 and 78.8 degrees Fahrenheit (°F) – with a relative humidity of the indoor air of 65 ± 7%. After 1 hour of acclimatization, individuals were asked to fill out the visual analogue scale and leave the chamber. During challenges individuals were asked to perform their daily intellectual activities on separate personal computers.

### Statistical analysis

Individual perception of IAQ was analyzed for each group by factor analysis using the principal components method and varimax rotation with Kaiser normalization. Factors (components) with eigenvalues > 1 and r > 0.30 were selected. The characteristics of study groups were compared using Chi-squared and Student's t tests. Differences between VAS scores were analyzed using the Mann Whitney U test.

### Results

In the chamber, we achieved air temperatures equivalent to radiant heat temperature. Considering that thermal protection of 1.0 CLO was used, we obtained thermal neutrality for an operative temperature around 22°C. Study compliance rate was 98.5%. One male volunteer did not complete the intermediate temperatures of 22 and 18°C due to suggestive symptoms of upper airways viral infection during the protocol.

Comparison of means: There was a significant gender difference concerning temperature perception. The female group reported a colder sensation than the male group at 14°C (p=0.016). All other IAQ perceptions did not differ between genders (Table 1).

Principal component analysis: At 14°C (57.2°F), three components were selected in the Female group. The first was responsible for 38.3% of the total variance and showed a correlation among good IAQ, feelings of freshness, well-being and easy mental concentration. The second component accounted for 21.6% of the total variance and showed a correlation between dryness and good IAQ, as opposed to a perception of stagnant air. The third component accounted for 16.5% of the total variance, correlating hot and dry indoor air perception (Table 2). In

Parameter	Temperature 14°C(57.2°F)			Temperature 18°C (64.4°F)			Temperature 22°C (71.6°F)			Temperature 26°C 78.8°F)		
	1	2	3	1	2	3	1	2	3	1	2	3
Hot air sensation		.831			.832			.797				-.760
Dry air sensation			.928		.581		-.433	.610				.765
Little ventilation (stagnant air)	-.774	.369		-.415	.669			.695			.882	
Good indoor air quality	.538		.664	.465	.396		.726	-.474			.768	
Easy mental concentration	.908			.898			.919			.797		
In good shape (fresh)	.319	.852		.844			.749	.406		.940		
Feeling good (well-being)	.872			.928			.764	-.321		.760		
Cumulative variance (%)	38.47	61.09	80.54	40.37	63.14		43.94	67.54		34.09	55.56	73.70
KMO	0.426			0.510			0.641			0.436		

**Table 3** - Principal components in male individuals at different temperatures. Rotated component matrix selected by principal component analysis for temperatures of 14, 18, 22, and 26°C (57.2, 64.4, 71.6, and 78.8°F) in male individuals. KMO= Keiser-Meyer-Olkin measure of sampling adequacy.

the Male group, three components were selected. The first component was responsible for 38.5% of the total variance (Component 1) and was characterized by a strong correlation among good IAQ, well-being, freshness, easy mental concentration and draughty feeling. The second component was responsible for 22.6% of the variance and showed a correlation among warmth, stagnant air and feelings of freshness. The third component was responsible for 19.5% of total variance and correlated the perceptions of dryness and good indoor air (Table 3).

At 18°C (64.4°F), three components were selected in the Female group. The first of these was responsible for 32.9% of total variance and showed a strong correlation among freshness, well-being, draughty and cold indoor air. The second component showed a correlation between dry and stagnant air, opposed to easy mental concentration and good IAQ perception, accounting for 24.1% of the total variance of this group. The last component showed a correlation between warmth, easy mental concentration and freshness. This component was responsible for 14.8% of the total variance in this group (Table 2). In the Male group two components were selected. The first component was responsible for 40.4% of the variance and showed a correlation among the perceptions of easy mental concentration, freshness, well-being, non-stagnant air and good indoor air. The second component, responsible for 22.8% of the total variance showed a correlation among perceptions of warmth, dryness, stagnant air and good IAQ (Table 3).

At 22°C (71.6°F), three components were selected in the Female group. The first one showed a correlation among non-dry (humid) air, draught, easy mental concentration, freshness and well-being, and was responsible for 42.4% of the total variance. The second component showed a correlation among warmth, dryness, easy mental concentration and a feeling of discomfort (not feeling good), and it was responsible for 14.9% of the variance (Table 2). Two components were selected in the Male group. The first component showed a strong correlation among easy mental concentration, freshness, well-being and good IAQ, which correlated inversely with dry air sensation. It was responsible for 43.9% of the total variance of this group. The second component showed a correlation among freshness, warmth, dryness, stagnant air perception, as opposed to well-being and good IAQ, and was responsible for 23.6% of the variance (Table 3).

At the temperature of 26°C (78.8°F), the Female group had three components. The first component showed a correlation among dryness, cold air, freshness, well-being and easy mental concentration, and it was responsible for 34.8% of the variance. The second component showed a correlation among warmth, non-dry (humid) sensation, good IAQ perception, and the feeling of well-being as well, and it was responsible for 21.7% of the variance. The third component showed

a correlation among perceptions of warmth, dryness and stagnant air, and was responsible for 17.4% of the total variance in this group (Table 2). In the Male group three components were selected. The first component showed a correlation among perceptions of freshness, easy mental concentration and well-being. It was responsible for 34.1% of the variance. The second component showed a correlation among sensations of stagnant air, good IAQ and easy mental concentration. It was responsible for 21.5% of the total variance. The third component showed a correlation between cold and dry air sensations, responsible for 18.1% of the total variance of this group (Table 3).

## Discussion

This study suggests that under standardized clothing protection both genders produce very similar patterns of indoor air perception at most temperatures, supporting evidence that cultural gender differences in clothing protection are a determinant factor. On the other hand in colder environments, around 14°C, the female group reported greater cold perception, suggesting gender-related differences in IAQ perception far from thermoneutrality.

Subjective perceptions are prone to be influenced by various personal factors including mood, personal confidence and other characteristics related to personality and circumstances. This could influence perceptions of well-being, mental concentration capacity and other subjective perceptions, but should not interfere with those of cold, heat, humidity and air quality. On the other hand, simulated conditions can eliminate job-related stress and dissatisfaction that consistently influence IAQ perception [9,17].

Factor analysis is a valuable tool in analyzing subjective data, but caution must be taken in interpreting the results. The clinical relevance of the findings should be judged carefully to avoid misleading information. Nonetheless, the results showed remarkable cumulative variances explained by the analyzed components, as well as strong associations, diminishing this bias.

The temperatures that were studied are those commonly found indoors as a result of artificial acclimatization [18]. Indoor temperatures around 14°C (57.2°F) are considered cold for normal indoor standards. Enhanced thermal perception to cold air has already been described as annoying to females [19] and could account for the higher overall rates of IAQ-related complaints noted by women. Surprisingly both groups had a very similar principal component analysis of IAQ perception, correlating good indoor air quality, easy mental concentration, freshness and well-being, apart from the female group showing an inverse correlation between these factors and stagnant air.

At 18°C (64.4°F), both groups also showed similarities, correlating freshness, well-being and draughty (non-stagnant) air. The Male group also correlated good indoor air and easy mental concentration, whereas the Female group correlated cold (non-hot) air perception and the preceding factors. The second component comparison at this temperature showed important differences concerning correlations between sensations of dry and stagnant air. While the Male group correlated good IAQ perception, dry and stagnant air, the female group showed a correlation among dry and stagnant air, poor IAQ and not feeling good (poor well-being). This component accounted for 22.8 and 24.1% of the total variance of the Male and Female group, respectively.

At 22°C (71.6°F), the first component also had similar profiles in both groups. A strong correlation among non-dry air, easy mental concentration, freshness and well-being appeared in both groups, whereas the Male group also correlated the above with good IAQ and the Female group correlated these sensations inversely with stagnant air. Total variance explained by this component (43.9 and 42.4) and KMO results were similar.

Indoor temperatures of 26°C (78.8°F) are normally exceedingly high and not recommended for indoor air settings. Similarities between the two groups were also evident at this temperature, in which there was a correlation among easy mental concentration, freshness and well-being. The female group also correlated dry and cold (non-hot) air among the preceding factors.

This finding supports the notion that clothing is a more important determinant than physiological differences concerning thermal perception between gender as previously reported [20]. Field studies recently conducted in hot-humid climates showed no significant differences (0.1°C) between males and females at an indoor operative temperature at which thermal sensation was most frequently neutral, although the rate of thermal dissatisfaction was higher among females than males [21].

## Conclusions

This study suggests that independent of comfort indices, males and females have a very similar pattern of thermal and indoor environment perception in experimental studies in the tropics. The practical implications of this study suggest that less stringent standards of social dressing in formal workplaces could lead to fewer disparities among gender thermal perception. Further field studies using this approach are needed to confirm this result.

## Acknowledgment

Dr. Graudenz thanks the Research Support Foundation of Sao Paulo (FAPESP) with Grants n° 03/0846-5 and 02/09082-5 for financial support and Fundação de Apoio a Pesquisa – Nove de Julho University for technical support. We are also grateful to Prof. Dr. Pedro Cortes for leading the research group.

## References

1. Maroni M (2004) [Indoor air quality and occupational health, past and present]. *G Ital Med Lav Ergon* 26: 353-363.
2. Ole Fanger P (2006) What is IAQ? *Indoor Air* 16: 328-334.
3. Seppänen OA, Fisk WJ (2004) Summary of human responses to ventilation. *Indoor Air* 14 Suppl 7: 102-118.

**Citation:** Graudenz GS, Paschoalin-Filho JA, Ribeiro AP, Tribess A (2013) Gender Influences in Indoor Air Quality Perception for Individuals in Tropical Climate. *Occup Med Health Aff* 1: 142. doi:[10.4172/2329-6879.1000142](https://doi.org/10.4172/2329-6879.1000142)

4. Graudenz GS, Oliveira CH, Tribess A, Mendes C Jr, Latorre MR, et al. (2005) Association of air-conditioning with respiratory symptoms in office workers in tropical climate. *Indoor Air* 15: 62-66.
5. Mendell MJ, Fisk WJ, Petersen MR, Hines CJ, Dong M, et al. (2002) Indoor particles and symptoms among office workers: results from a double-blind cross-over study. *Epidemiology* 13: 296-304.
6. Bachmann MO, Turck WA, Myers JE (1995) Sick building symptoms in office workers: a follow-up study before and one year after changing buildings. *Occup Med (Lond)* 45: 11-15.
7. Soine L (1995) Sick building syndrome and gender bias: imperiling women's health. *Soc Work Health Care* 20: 51-65.
8. Bullinger M, Morfeld M, von Mackensen S, Brasche S (1999) The sick-building-syndrome—do women suffer more? *Zentralbl Hyg Umweltmed* 202: 235-241.
9. Ooi PL, Goh KT (1997) Sick building syndrome: an emerging stress-related disorder? *Int J Epidemiol* 26: 1243-1249.
10. Liou JT, Lui PW, Lo YL, Liou L, Wang SS, et al. (1999) Normative data of quantitative thermal and vibratory thresholds in normal subjects in Taiwan: gender and age effect. *Zhonghua Yi Xue Za Zhi (Taipei)* 62: 431-437.
11. van Hoof J, Mazej M, Hensen JL (2010) Thermal comfort: research and practice. *Front Biosci (Landmark Ed)* 15: 765-788.
12. Brasche S, Bullinger M, Bronisch M, Bischof W (2001) Eye- and skin symptoms in German office workers—subjective perception vs. objective medical screening. *Int J Hyg Environ Health* 203: 311-316.
13. Bascom R (1991) The upper respiratory tract: mucous membrane irritation. *Environ Health Perspect* 95: 39-44.
14. Kildesø J, Wyon D, Skov T, Schneider T (1999) Visual analogue scales for detecting changes in symptoms of the sick building syndrome in an intervention study. *Scand J Work Environ Health* 25: 361-367.
15. Light IM, Dingwall RH, Norman JN (1980) The thermal protection offered by lightweight survival systems. *Aviat Space Environ Med* 51: 1100-1103.
16. Pereira ML, Graudenz GS, Tribess A, Morawska L (2009) Determination of particle concentration in the breathing zone for four different types of office ventilation systems. *Building and Environment* 904-911.
17. Bachmann MO, Myers JE (1995) Influences on sick building syndrome symptoms in three buildings. *Soc Sci Med* 40: 245-251.
18. ASHRAE (1989) Standart-Ventilation for Acceptable Indoor Air Quality. American Society of Heating, Refrigerating and Air-Conditioning Engineers Inc 62.
19. Pellerin N, Candas V (2003) Combined effects of temperature and noise on human discomfort. *Physiol Behav* 78: 99-106.
20. Blankenburg M, Meyer D, Hirschfeld G, Kraemer N, Hechler T, et al. (2011) Developmental and sex differences in somatosensory perception—a systematic comparison of 7- versus 14-year-olds using quantitative sensory testing. *Pain* 152: 2625-2631.
21. Erlandson T, Cena K, De Dear R, Havenith G (2003) Environmental and human factors influencing thermal comfort of office occupants in hot - humid and hot - arid climates. *Ergonomics* 46: 616-628.

## Submit your next manuscript and get advantages of OMICS Group submissions

### Unique features:

- User friendly/feasible website-translation of your paper to 50 world's leading languages
- Audio Version of published paper
- Digital articles to share and explore

### Special features:

- 300 Open Access Journals
- 25,000 editorial team
- 21 days rapid review process
- Quality and quick editorial, review and publication processing
- Indexing at PubMed (partial), Scopus, EBSCO, Index Copernicus and Google Scholar etc
- Sharing Option: Social Networking Enabled
- Authors, Reviewers and Editors rewarded with online Scientific Credits
- Better discount for your subsequent articles

Submit your manuscript at: [www.omicsonline.org/submission/](http://www.omicsonline.org/submission/)









